



COMMUNITY DEVELOPMENT DEPARTMENT • BUILDING INSPECTION DIVISION
500 Castro Street • Post Office Box 7540 • Mountain View, California 94039-7540
650-903-6313 • FAX 650-962-8501

EMERGENCY RESPONDER RADIO SYSTEM SUBMITTAL REQUIREMENTS

This document will outline the submittal requirements for radio coverage systems. This is a supplemental permit to the original construction permit, please provide the original permit number and address at submittal.

Applicants are required to submit plans and applications directly to the Building Inspection Division during regular business hours. Plans will not be accepted by mail. The Building Division is located at 500 Castro Street in City Hall on the first floor in the Community Development Department.

Any questions should be directed to the Fire Protection Engineers, they can be reached at (650) 903-6313.

Thank you for your cooperation,
Mountain View Building Inspection Division

EMERGENCY RESPONDER PLAN CHECK REQUIREMENTS AND SCHEDULES

A minimum plan size of 18" x 24" is required for all submittals. All plans submitted must be legible because they will be digitally imaged as a permanent record after the project has been completed.

- A. Plan Check Period
 - 1. Two (2) weeks
- B. Recheck Period
 - 1. Two (2) weeks
- C. Plan Check Submittal Requirements
 - 1. Five (5) sets of plans with site plans - *Two (2) copies wet stamped & signed by AOR/EOR*
 - 2. Four (4) copies equipment specifications
 - 3. Two (2) sets of structural calculations as required - *wet stamped & signed*
 - 4. Fire Alarm may be required as a separate submittal package

TECHNICAL CRITERIA

MOUNTAIN VIEW PUBLIC SAFETY TECHNICAL CRITERIA

Channel	Repeater Input "Uplink" Frequencies	Repeater Output "Downlink" Frequencies	Location
PD-1	485.5125 Tx	482.5125 Rx	1000 Villa Street
PD-3	485.7875 Tx	482.7875 Rx	444 Castro Street
PD-4	486.2125 Tx	483.2125 Rx	1000 Villa Street
FD Primary	154.995 Tx	154.025 Rx	1000 Villa Street
FD Cmd-18	155.610 Tx	154.830 Rx	444 Castro Street